

MGU INNOVATION FOUNDATION

(Section 8 company under the Companies Act, 2013)

MAHATMA GANDHI UNIVERSITY

Priyadarshini Hills, Kottayam-686560, Kerala, India



CIN: U85300KL2019NPL060819

GSTIN: 32AANCM1695D1ZH

Date: 22-05-2024

No: MGUIF/QN/02/2024-25

QUOTATION NOTICE

Connection for EV Charging station at MGU Innovation Foundation (MGUIF), Mahatma Gandhi University Campus, Priyadarsini Hills PO, Kottayam, subject to the terms and conditions listed below:

| Sl No | Specification | Qty |
|-------|--|------|
| 1 | Providing Three Phase Commercial Connection for EV | 1 No |
| | Charging station. (Scope of Work) | |

Last date & time for the receipt of Quotation: 30.05.2024 before 5.00 pm

Date and time of opening of Quotation: 31.05.2024 after 10.30 am

Terms and Conditions -

- 1. Quoted price shall include all taxes and duties and loading, unloading and other installation charges.
- 2. Price shall be valid for 30 Days from the date of quotation opening.
- 3. Warranty shall be provided for a minimum of 1 year.
- 4. The right to accept or reject the quotation without assigning any reasons rests entirely with the undersigned.
- 5. If the last date for the receipt of the quotation is declared a holiday, then the next day will be considered for the purpose.
- Quotes in sealed covers shall be sent to "The Chief Operating Officer, MGU Innovation Foundation, MG University Campus, Priyadarsini Hills PO, Kottayam, Kerala. PIN 686 560"

Attached: Scope of Work.

Mahatma Gandhi University
Kottayam - India

Chairman & Managing Director

MGU Innovation Foundation







| Scope of Work | | | | |
|---------------|--|-----|-------|--|
| Sl No | Description | QTY | Unit | |
| 1 | Supply and fixing of following sizes of light gauge PVC conduit along with accessories in surface/ recess including cutting the wall and making good the same incase of recessed conduit as required 20 | | mtr | |
| 2 | with accessories in surface/ recess including cutting the wall and making good the same in case of recessed conduit as required 32 mm | 2 | mtr | |
| 3 | Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface / recessed steel/ PVC conduit as required.4 x 10 sq. mm | | mtr * | |
| 4 | Earthing with G.I. earth plate 600 mm X 600 mm X 6 mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe with charcoal/coke and salt as required. | | Nos | |
| 5 | Supply and drawing bare earthing conductors of the following sizes along with wiring/ cables and giving connection as required3.15 mm copper conductor (10 SWG) | 25 | Nos | |
| 6 | Supply and fixing of three phase meter box sintex make | 1 | Nos | |
| 7 | Supply and fixing of 63 A fuse unit with fuse link | 3 | Nos | |
| 8 | Supply and fixing of 63 A Neutral link | 1 | Nos | |
| 9 | Supply and installation of copper lug | 16 | Nos | |
| 10 | Supplying and fixing following rating, four pole, (three phase and neutral), 415 volts, residual current circuit breaker (RCCB), having a sensitivity current upto 300 milliamperes in the existing MCB DB complete with connections, testing and commissioning etc. as required.63 amps | 1 | Nos | |
| 11 | Supply and installation of sheet steel, phosphatised and painted, dust and vermin proof enclosure of MCB DB including copper /brass bus bar, neutral link, earth bus and DIN rail suitable for fixing MCB/ isolator etc. fixed on wall using suitable anchor bolts or fixed in recess including cutting hole on the wall, making good the damages, colour washing etc. as required4 way (8+12) - double cover TPN vertical DB with provision for fixing 4P MCB / Isolator/ RCCB/ RCBO as incomer and SP/ TP MCB as outgoing (IP 42/43) | | Nos | |
| 12 | Supplying and fixing following size/modules, Plastic box along with cover plate, 3 numbers of straight battern holder, switches and bulb | | | |
| 13 | Civil works for making wall for fixing meter box and DB | 1 | Nos | |

